



**OFFICE OF THE DEPUTY FIRE OFFICER  
BALASORE CIRCLE BALASORE**

**FORM-V  
FIRE SAFETY CERTIFICATE**

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No-15 (a)/2019 BLS CLE

Certificate No-02/BLS CLE

Dt-25.01.2022

This certificate is valid up to **24.01.2024**  
(Apply for renewal at least three months before expiry)

Certified that Balasore Technical Education Society, Ranipatna, over Plot No-252 & 351, Khata No-329/1767, Mouza-Srikantapur, Ps- Balasore town, Dist-Balasore consisting of 03 Nos of Block were inspected by officers of Odisha Fire Service on 07.02.2019 and re-inspection on 09.11.2020 & 24.01.2022 in presence of the President, Balasore Technical Education Society, Ranipatna, Dist-Balasore and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019 and one time relaxation scheme vide Home Department Notification No-28550/CD BBSR dtd-28.08.2020 . Hence, its various floors are fit from fire safety point of view for occupancy or usage as noted hereunder against each, subject to compliance to the conditions as prescribed herein below:

**Academic Building**

G Floor-	--- usage---	Class Room-04 Nos & Girls common Room-01 No
1 <sup>st</sup> Floor -	--- usage---	Class Room-04 Nos & Library-01 No
2 <sup>nd</sup> Floor -	--- usage---	Class Room-05 Nos

**Electrical Engineering & Electrical & Electronic Engineering Building**


G Floor-	--- usage---	Lab-05 Nos
1 <sup>st</sup> Floor -	--- usage---	Lab-05 Nos
2 <sup>nd</sup> Floor -	--- usage---	Class room

**Mechanical Building**

G Floor-	--- usage---	Mechanical lab-06 Nos
1 <sup>st</sup> Floor -	--- usage---	Computer Lab-04 Nos & Class Room-02 Nos
2 <sup>nd</sup> Floor -	--- usage---	Class Room-06 Nos

**CONDITIONS:-**


1. Fire Prevention and safety measures and appliances, availability of water supplies and means of access thereto etc. provided in the building or premises, should be maintained by the occupier (S) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier (S) shall train all staff and occupants periodically to make them well conversant in use and operation of fire prevention and safety measures.
4. Fire drills/rehearsals should be organized at least once in six months by involving local Fire Station.
5. Photocopies of this certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all tower/blocks of building/premises.
6. The owner or occupier is required to regularize the deviation by the plan approving authority of jurisdiction as per guideline issued by Urban Development Department.

  
 (Satyapir Behera)  
 Deputy Fire Officer  
 Balasore Circle, Balasore

Memo No-139/BLS CLE

date.25.01.2022

Copy submitted to the President, Balasore Technical Education Society, Ranipatna, over Plot No-252, Khata No-329/1767, Mouza-Srikantapur, Ps- Balasore town, Dist-Balasore along with Form-IV for information and necessary action for regularize the pl in.



(Satyapir Behera)  
Deputy Fire Officer  
Balasore Circle, Balasore  
**Deputy Fire Officer**  
Balasore Circle, Balasore

Memo No- /BLS CLE

date. .01.2022

Copy submitted to the Balasore Regional Improvement Trust, Balasore along with Form-IV for information and necessary action please.

Sd/-  
(Satyapir Behera)  
Deputy Fire Officer  
Balasore Circle, Balasore

Memo No- /BLS CLE

date. .01.2022

Copy submitted to the Chief Fire Officer, Fire Prevention Wing, Directorate, Cuttack for information please.

Sd/-  
(Satyapir Behera)  
Deputy Fire Officer  
Balasore Circle, Balasore

Memo No- /BLS CLE

date. .01.2022

Copy forwarded to the Asst. Fire Officer, Balasore Fire Station for information and necessary action.

Sd/-  
(Satyapir Behera)  
Deputy Fire Officer  
Balasore Circle, Balasore